

10	Класс	Д	49.3	400	3	Г-0.8	15	OPL/R	4	12	1200	18	0.864						0.864	
		Д		500	2.5	В-15	15	ASM	2	1	2850	36	0.072						0.072	
11	Класс	Д	50.4	400	3	Г-0.8	15	OPL/R	4	12	1200	18	0.864						0.864	
		Д		500	2.5	В-15	15	ASM	2	1	2850	36	0.072						0.072	
12	Класс	Д	49.4	400	3	Г-0.8	15	OPL/R	4	12	1200	18	0.864						0.864	
		Д		500	2.5	В-15	15	ASM	2	1	2850	36	0.072						0.072	
13	Класс	Д	49.8	400	3	Г-0.8	15	OPL/R	4	12	1200	18	0.864						0.864	
		Д		500	2.5	В-15	15	ASM	2	1	2850	36	0.072						0.072	
14	Класс	Д	26.6	400	3	Г-0.8	15	OPL/R	4	9	1200	18	0.648						0.648	
		Д		500	2.5	В-15	15	ASM	2	1	2850	36	0.072						0.072	
15	Класс	Д	23	400	3	Г-0.8	15	OPL/R	4	8	1200	18	0.576						0.576	
		Д		500	2.5	В-15	15	ASM	2	1	2850	36	0.072						0.072	
16	Кладовая	П-Иа	16	75	2.5	пол	15	НППОЗ	1	2	1200	100	0.2						0.2	
17	Кабинет	Д	9.8	300	3	Г-0.8	15	ARS/R	4	2	1200	18	0.144						0.144	
18	Санузел	Влажное	9.8	75	3	пол	15	ALD	2	1	2850	36	0.072						0.072	
19	Кладовая	П-Иа	16	75	2.5	пол	15	НППОЗ	1	2	1200	100	0.2						0.2	
20	Лестничная клетка	Д	25.9	100	2.5	пол	15	АОТ.OPL	2	3	2850	36	0.216	АОТ.OPL	1	2850	0.072		0.288	
4 этаж																				
1	Коридор	Д	186.7	100	3	пол	15	ОТХ	2	8	4600	55	0.88	ОТХ	3	4600	0.33	0.33	1.54	
2	Класс	Д	65.1	400	3	Г-0.8	15	ARS/R	4	12	1200	18	0.864						0.864	
														МК-4/29.08-30.Р1						Лист
																				5
														Изм.	Кол.уч.	Лист	№ док.	Подп.	Дата	